


# Solar Energy Estimate

## PV System Good Faith Estimate

Estimate Provided By:



Sunenergy Solar  
David Crowford  
(408) 766-5998  
dcrowford@sunergy.com


### 7,293 kWh (AC)

First year estimated energy

### 171,782 kWh (AC)

25 year estimated energy

Only for comparison across systems. Actual output will vary.



#### SITE DATA

Project Name: Thomas Gallo Residence  
Location: 1290 Parkmoor Avenue  
San Jose, CA, 95126  
Climate Cell: 174348

#### PV SYSTEM SPECIFICATIONS

Module: <b>Mitsubishi Electric PV-UD185MF5</b>	Array Tilt: <b>18 Degrees</b>
Module Qty: <b>27</b>	Array Azimuth: <b>195 Degrees</b>
Module Derate: <b>0.97 (based on mfr's lower tolerance data within SolarHub)</b>	Array Type: <b>Fixed Tilt</b>
Inverter: <b>ZIGOR SUNZET 5 TL-US</b>	Mounting Method: <b>&gt;3" to 6" average standoff</b>
Inverter Qty: <b>1</b>	
Inverter Derate: <b>0.955 (CEC weighted efficiency)</b>	

#### ABOUT REPORT

This good faith estimate enables relative comparisons across different systems to facilitate consumer buying decisions. Actual output may vary. Details about calculation methodology are available at [solarhub.com/SEE-Report-Methodology](http://solarhub.com/SEE-Report-Methodology). For more information, visit [www.solartech.org/SEE](http://www.solartech.org/SEE)

Report Generated By: SolarHub.com  
Estimate Date: 10/15/11  
SEE Report Version: 1.0

## Solar Energy Estimate

Brought to you by  SolarTech  
An initiative of Silicon Valley Leadership Group